Phone Off: 080-22961935 / 1946
E-mail: centrans9@gmail.com

BANGALORE UNIVERSITY
DEPARTMENT OF CIVIL ENGINEERING

JNANA BHARATHI
BANGALORE - 560 056

BUB/CTE/2016-17/

1. TESTING OF FINE AGGREGATES: **Date: 04-04-2016**

Sub: Testing of Fine Aggregates.
{Project*: Improvements to Roads and Drains at M.S.Palya and surrounding roads in Ward No.11 Vidyaranyapura Sub-Division}
Ref.: Letter No. Testing/BUB/2016-17, dated 01-04-2016
Sample Supplied to lab by : Sri. K.S.Chowdareddy, Contractor ,Bangalore
Report required for: Assistant Executive Engineer,
Vidyaranyapura, Sub-Division
BBMP, Bangalore.

TABLE - 1.1 : SIEVE ANALYSIS :

IS Sieve Size, mm	Percentage Passing	Specification as Per IS: 383-1970(Reaffirmed 2002) Percentage Passing			Remarks
		Zone-I	Zone-II	Zone -III	
04.75	98.40	90-100	90-100	90-100	The Sample Conforms to Grading **Zone-II**
02.36	85.30	60-95	75-100	85-100	
01.18	74.50	30-70	55-90	75-100	
600. mic	44.20	15-34	35-59	60-79	
300.mic	19.50	5-20	8-30	12-40	
150.mic	2.80	0-10	0-10	0-10	

ASSISTANT EXECUTIVE ENGINEER
Vidyaranyapura Sub-Division
Bruhath Bengaluru Mahanagara Palike

TABLE 1.2 ;

Sl No	Test Conducted	Sample	Results	Requirements as Per IS. Specification IS :383-1970 (Reaffirmed 2002)
1	Silt Content	001	1.46 %	Not more than 8%
2.	Specific Gravity	----	2.58	-------

*As furnished by Client.
The Results relate only to the items tested.

G.R. HARISH
Professor
Department of Civil Engineering
Jnana Bharathi Compus
BANGALORE UNIVERSITY
Bangalore-560 056.

4/4/2016
Dr. MANJESH .L
ME(Civil Engg.) Ph.D., MISTE, MIRC
Associate Professor
Department of Civil Engineering
Bangalore University, Jnanabharathi Campus,
BANGALORE 560 056.
E-mail: maniesnl@yahoo.com

Phone Off: 080-22961935 / 1946
E-mail: centrans9@gmail.com

BANGALORE UNIVERSITY
DEPARTMENT OF CIVIL ENGINEERING

JNANA BHARATHI
BANGALORE - 560 056

BUB/CTE/2016-17/

1. TEST REPORT ON CEMENT:

Date: 11-04-2016

Sub: Testing of 53 Grade Cement Sample (IS 12269-1987).
{Project*: Improvements to Roads and Drains at M.S.Palya and surrounding roads in Ward No.11 Vidyaranyapura Sub-Division}

Ref.: Letter No. Testing/BUB/2016-17, dated 01-04-2016

Sample Supplied to lab by : Sri. K.S.Chowdareddy, Contractor ,Bangalore

Report required for: Assistant Executive Engineer,
Vidyaranyapura, Sub-Division
BBMP, Bangalore.

PHYSICAL TESTS ON CEMENT

Brand* : Birla Super
Grade * : 53
Type * : OPC
Date : 02-04-2016 to 09-04-2016

SL No	Name of Test	Results	Requirements as per
		Cement Sample	IS 12269-1987
1	Initial setting time	**165 min**	Shall not be less than 30 min
2	Final setting time	**270 min**	Shall not be more than 600 min
3	Fineness (by dry sieving on IS 90 micron sieve)	**2.50%**	Not to exceed 10.0%
4	Soundness test(by Le-Chatelier's method)	**1.42mm**	Shall not be more than 10 mm
5	Compressive strength a) 3 days (average of three results) b) 7 days (average of three results)	**29.80 Sq mm** **41.50 N/Sq mm**	Shall not be less than 27 N/Sqmm Shall not be less than 37N/Sqmm

*As furnished by Client.

The Results relate only to the items tested.

G.R. HARISH
Professor
Department of Civil Engineering
Jnana Bharathi Compus
BANGALORE UNIVERSITY
Bangalore-560 056.

11/4/16

Dr. MANJESH .L
ME(Civil Engg.) Ph.D., MISTE, MIRC
Associate Professor
Department of Civil Engineering
Bangalore University. Jnanabharathi Campus,
BANGALORE 560 056.
E-mail: maniesnl@yahoo.com

Phone Off: 080-22961935 / 1946
E-mail: centrans9@gmail.com

BANGALORE UNIVERSITY
DEPARTMENT OF CIVIL ENGINEERING

JNANA BHARATHI
BANGALORE - 560 056

FOR QUALITY & EXCELLENCE IN HIGHER EDUCATION
Accredited by NAAC

BUB/CTE/2016-17/

Date: 04-04-2016

1. TEST REPORT ON REINFORCEMENT STEEL :

Sub: Testing of Reinforcement Steel of diameter 10mm.
{Project*: Improvements to Roads and Drains at M.S.Palya and surrounding roads in Ward No.11 Vidyaranyapura Sub-Division}

Ref.: Letter No. Testing/BUB/2016-17, dated 01-04-2016
Sample Supplied to lab by : Sri. K.S.Chowdareddy, Contractor ,Bangalore
Report required for: Assistant Executive Engineer,
Vidyaranyapura, Sub-Division
BBMP, Bangalore.

TABLE – 1

SL No	Details	For 10 mm	
		Test Results	Min Req. as per IS 1786-2008
01	Observed diameter of bar	**10.0mm**	10.0mm
02	Observed Wt/m Length **Kg/m**	**0.620**	0.567
03	Proof stress/Yield stress, fy , **N/mm^2**	**556.0**	500.0
04	Bend/ Re bend Test	**Ok**	---
05	Percentage of Elongation, %	**19.80**	12.00
06	Ultimate Tensile Strength **N/mm^2**	**632.0**	545.0

*As furnished by Client.
The Results relate only to the items tested.

G.R. HARISH
Professor
Department of Civil Engineering
Jnana Bharathi Campus
BANGALORE UNIVERSITY
Bangalore-560 056.

04/04/16
Dr. MANJESH .L
ME(Civil Engg.) Ph.D., MISTE, MIRC
Associate Professor
Department of Civil Engineering
Bangalore University. Jnanabharathi Campus,
BANGALORE 560 056.
E-mail: maniesnl@yahoo.com

Phone Off: 080-22961935 / 1946
E-mail: centrans9@gmail.com

BANGALORE UNIVERSITY
DEPARTMENT OF CIVIL ENGINEERING

JNANA BHARATHI
BANGALORE - 560 056

FOR QUALITY & EXCELLENCE IN HIGHER EDUCATION
Accredited by NAAC

BUB/CTE/2016-17/

1. TESTING OF COARSE AGGREGATES (40 mm): **Date: 04-04-2016**

Sub: Testing of Coarse Aggregates.
{Project*: Improvements to Roads and Drains at M.S.Palya and surrounding roads in Ward No.11 Vidyaranyapura Sub-Division}
Ref.: Letter No. Testing/BUB/2016-17, dated 01-04-2016
Sample Supplied to lab by : Sri. K.S.Chowdareddy, Contractor ,Bangalore
Report required for: Assistant Executive Engineer,
Vidyaranyapura, Sub-Division
BBMP, Bangalore.

Table - 1.1 : SIEVE ANALYSIS :

IS Sieve Size, mm	Percentage passing	Requirements as per IS 383-1970 (Reaffirmed on 2002) % Passing	
	40 mm Sample	*Single size*	*Graded*
40mm	97.50	85-100	95 – 100
20mm	38.00	0 -20	30- 70
10mm	19.50	0 -5	10- 35
4.75mm	Nil	------	0 - 5

TABLE 1 2 :

SL No	Test conducted	Sample No	Results	Requirements as per IS:383-1970 & Test Conforms to IS 2386(Part I to IV) – 1963 (Reaffirmed on 2002)
1.	Flakiness Index	As above	15.42%	Not to exceed 25 %
2.	Crushing value	----,,----	26.42 %	Not to exceed 45 % for concrete other than for wearing surfaces and 30% for concrete for wearing surfaces

*As furnished by Client.
The Results relate only to the items tested.

G.R. HARISH
Professor
Department of Civil Engineering
Jnana Bharathi Compus
BANGALORE UNIVERSITY.
Bangalore-560 056.

Dr. MANJESH .L
ME(Civil Engg.) Ph.D., MISTE, MIRC
Associate Professor
Department of Civil Engineering
Bangalore University, Jnanabharathi Campus,
BANGALORE 560 056.
E-mail: maniesnl@yahoo.com

FOR QUALITY & EXCELLENCE IN HIGHER EDUCATION
Accredited by NAAC

Phone Off: 080-22961935 / 1946
E-mail: centrans9@gmail.com

BANGALORE UNIVERSITY
DEPARTMENT OF CIVIL ENGINEERING

JNANA BHARATHI
BANGALORE - 560 056

BUB/CTE/2016-17/

DATE: 14-05-2016

1. TEST REPORT ON CEMENT CONCRETE CUBES :

Sub: Testing of Concrete Cubes (28days Compressive Strength)
{Project*: Improvements to Roads and Drains at M.S.Palya and surrounding roads in Ward No.11 Vidyaranyapura Sub-Division}

Ref.: Letter No. Testing/BUB/2016-17, dated 13-05-2016

Sample Supplied to lab by : Sri. K.S.Chowdareddy, Contractor ,Bangalore

Report required for: Assistant Executive Engineer,
Vidyaranyapura, Sub-Division
BBMP, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm
Grade of Concrete* : M20
Location Concrete* : CC Road

TABLE 1.1 :

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in Mm^2	Maximum Load in K.N	Compressive Strength (N/mm^2)	Avg. Value
1	001	15-04-16	13-05-16	28	22500	520	23.11	**23.33**
	002	"	"	"	"	530	23.55	
	003	"	"	"	"	525	23.33	

*As Furnished by Client.

The Results relate only to the items tested.

G.R. HARISH
Professor
Department of Civil Engineering
Jnana Bharathi Compus
BANGALORE UNIVERSITY
Bangalore-560 056.

Dr. MANJESH .L
ME(Civil Engg.) Ph.D., MISTE, MIRC
Associate Professor
Department of Civil Engineering
Bangalore University, Jnanabharathi Campus,
BANGALORE 560 056.
E-mail: maniesnl@yahoo.com

Phone Off: 080-22961935 / 1946
E-mail: centrans9@gmail.com

BANGALORE UNIVERSITY
DEPARTMENT OF CIVIL ENGINEERING

JNANA BHARATHI
BANGALORE - 560 056

BUB/CTE/2016-17/

DATE: 17-05-2016

1. TEST REPORT ON CEMENT CONCRETE CUBES :

Sub: Testing of Concrete Cubes (28days Compressive Strength)
{Project*: Improvements to Roads and Drains at M.S.Palya and surrounding roads in Ward No.11 Vidyaranyapura Sub-Division}

Ref.: Letter No. Testing/BUB/2016-17, dated 16-05-2016

Sample Supplied to lab by : Sri. K.S.Chowdareddy, Contractor ,Bangalore

Report required for: Assistant Executive Engineer,
Vidyaranyapura, Sub-Division
BBMP, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm
Grade of Concrete* : M20
Location Concrete* : CC Road

TABLE 1.1 :

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in Mm^2	Maximum Load in K.N	Compressive Strength (N/mm^2)	Avg. Value
1	001	18-04-16	16-05-16	28	22500	520	23.11	**22.66**
	002	"	"	"	"	500	22.22	
	003	"	"	"	"	510	22.66	

*As Furnished by Client.

The Results relate only to the items tested.

G.R. HARISH
Professor
Department of Civil Engineering
Jnana Bharathi Campus
BANGALORE UNIVERSITY
Bangalore-560 056.

Dr. MANJESH .L
ME(Civil Engg.) Ph.D., MISTE, MIRC
Associate Professor
Department of Civil Engineering
Bangalore University, Jnanabharathi Campus,
BANGALORE 560 056.
E-mail: manjesnl@yahoo.com

Phone Off: 080-22961935 / 1946
E-mail: centrans9@gmail.com

BANGALORE UNIVERSITY
DEPARTMENT OF CIVIL ENGINEERING

JNANA BHARATHI
BANGALORE - 560 056

BUB/CTE/2016-17/

DATE: 17-05-2016

1. TEST REPORT ON CEMENT CONCRETE CUBES :

Sub: Testing of Concrete Cubes (28days Compressive Strength)
{Project*: Improvements to Roads and Drains at M.S.Palya and surrounding roads in Ward No.11 Vidyaranyapura Sub-Division}

Ref.: Letter No. Testing/BUB/2016-17, dated 16-05-2016

Sample Supplied to lab by : Sri. K.S.Chowdareddy, Contractor ,Bangalore

Report required for: Assistant Executive Engineer,
Vidyaranyapura, Sub-Division
BBMP, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm
Grade of Concrete* : M20
Location Concrete* : CC Road

TABLE 1.1 :

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in Mm^2	Maximum Load in K.N	Compressive Strength (N/mm^2)	Avg. Value
1	001	18-04-16	16-05-16	28	22500	495	22.00	**22.22**
	002	"	"	"	"	510	22.66	
	003	"	"	"	"	495	22.00	

*As Furnished by Client.

The Results relate only to the items tested.

G.R. HARISH
Professor
Department of Civil Engineering
Jnana Bharathi Campus
BANGALORE UNIVERSITY
Bangalore-560 056.

Dr. MANJESH .L
ME(Civil Engg.) Ph.D., MISTE, MIRC
Associate Professor
Department of Civil Engineering
Bangalore University, Jnanabharathi Campus,
BANGALORE 560 056.
E-mail: maniesnl@yahoo.com

Phone Off: 080-22961935 / 1946
E-mail: centrans9@gmail.com

BANGALORE UNIVERSITY
DEPARTMENT OF CIVIL ENGINEERING

JNANA BHARATHI
BANGALORE - 560 056

FOR QUALITY & EXCELLENCE IN HIGHER EDUCATION
Accredited by NAAC

BUB/CTE/2016-17/

DATE: 17-05-2016

1. TEST REPORT ON CEMENT CONCRETE CUBES :

Sub: Testing of Concrete Cubes (28days Compressive Strength)
{Project*: Improvements to Roads and Drains at M.S.Palya and surrounding roads in Ward No.11 Vidyaranyapura Sub-Division}

Ref.: Letter No. Testing/BUB/2016-17, dated 16-05-2016

Sample Supplied to lab by : Sri. K.S.Chowdareddy, Contractor ,Bangalore

Report required for: Assistant Executive Engineer,
Vidyaranyapura, Sub-Division
BBMP, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm
Grade of Concrete* : M20
Location Concrete* : CC Road

TABLE 1.1 :

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in Mm^2	Maximum Load in K.N	Compressive Strength (N/mm^2)	Avg. Value
1	001	18-04-16	16-05-16	28	22500	520	23.11	**23.62**
	002	"	"	"	"	535	23.77	
	003	"	"	"	"	540	24.00	

*As Furnished by Client.

The Results relate only to the items tested.

G.R. HARISH
Professor
Department of Civil Engineering
Jnana Bharathi Compus
BANGALORE UNIVERSITY
Bangalore-560 056.

Dr. MANJESH .L
ME(Civil Engg.) Ph.D., MISTE, MIRC
Associate Professor
Department of Civil Engineering
Bangalore University. Jnanabharathi Campus,
BANGALORE 560 056.
E-mail: maniesnl@yahoo.com

Phone Off: 080-22961935 / 1946
E-mail: centrans9@gmail.com

BANGALORE UNIVERSITY
DEPARTMENT OF CIVIL ENGINEERING

JNANA BHARATHI
BANGALORE - 560 056

BUB/CTE/2016-17/

DATE: 17-05-2016

1. TEST REPORT ON CEMENT CONCRETE CUBES :

Sub: Testing of Concrete Cubes (28days Compressive Strength)
{Project*: Improvements to Roads and Drains at M.S.Palya and surrounding roads in Ward No.11 Vidyaranyapura Sub-Division}

Ref.: Letter No. Testing/BUB/2016-17, dated 16-04-2016

Sample Supplied to lab by : Sri. K.S.Chowdareddy, Contractor ,Bangalore

Report required for: Assistant Executive Engineer,
Vidyaranyapura, Sub-Division
BBMP, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm
Grade of Concrete* : M20
Location Concrete* : CC Road

TABLE 1.1 :

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in Mm^2	Maximum Load in K.N	Compressive Strength (N/mm^2)	Avg. Value
1	001	18-04-16	16-05-16	28	22500	520	23.11	**23.18**
	002	"	"	"	"	535	23.77	
	003	"	"	"	"	510	22.66	

*As Furnished by Client.

The Results relate only to the items tested.

G.R. HARISH
Professor
Department of Civil Engineering
Jnana Bharathi Compus
BANGALORE UNIVERSITY
Bangalore-560 056.

Dr. MANJESH .L
ME(Civil Engg.) Ph.D. MISTE, MIRC
Associate Professor
Department of Civil Engineering
Bangalore University. Jnanabharathi Campus,
BANGALORE 560 056.
E-mail: maniesnl@yahoo.com

Phone Off: 080-22961935 / 1946
E-mail: centrans9@gmail.com

FOR QUALITY & EXCELLENCE IN HIGHER EDUCATION
Accredited by NAAC

BANGALORE UNIVERSITY
DEPARTMENT OF CIVIL ENGINEERING

JNANA BHARATHI
BANGALORE - 560 056

BUB/CTE/2016-17/

DATE: 14-05-2016

1. TEST REPORT ON CEMENT CONCRETE CUBES :

Sub: Testing of Concrete Cubes (28days Compressive Strength)
{Project*: Improvements to Roads and Drains at M.S.Palya and surrounding roads in Ward No.11 Vidyaranyapura Sub-Division}

Ref.: Letter No. Testing/BUB/2016-17, dated 13-05-2016

Sample Supplied to lab by : Sri. K.S.Chowdareddy, Contractor ,Bangalore

Report required for: Assistant Executive Engineer,
Vidyaranyapura, Sub-Division
BBMP, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm
Grade of Concrete* : M20
Location Concrete* : CC Road

TABLE 1.1 :

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in Mm^2	Maximum Load in K.N	Compressive Strength (N/mm^2)	Avg. Value
1	001	15-04-16	13-05-16	28	22500	530	23.33	**23.40**
	002	"	"	"	"	515	22.88	
	003	"	"	"	"	540	24.00	

*As Furnished by Client.

The Results relate only to the items tested.

G.R. HARISH
Professor
Department of Civil Engineering
Jnana Bharathi Compus
BANGALORE UNIVERSITY
Bangalore-560 056.

Dr. MANJESH .L
ME(Civil Engg.) Ph.D.. MISTE, MIRC
Associate Professor
Department of Civil Engineering
Bangalore University, Jnanabharathi Campus,
BANGALORE 560 056.
E-mail: maniesnl@yahoo.com

FOR QUALITY & EXCELLENCE IN HIGHER EDUCATION
★ ★ ★ ★ ★
Accredited by NAAC

BANGALORE UNIVERSITY
DEPARTMENT OF CIVIL ENGINEERING

Phone Off: 080-22961935 / 1946
E-mail: centrans9@gmail.com

JNANA BHARATHI
BANGALORE - 560 056

BUB/CTE/2016-17/

DATE: 15-05-2016

1. TEST REPORT ON CEMENT CONCRETE CUBES :

Sub: Testing of Concrete Cubes (28days Compressive Strength)
{Project*: Improvements to Roads and Drains at M.S.Palya and surrounding roads in Ward No.11 Vidyaranyapura Sub-Division}

Ref.: Letter No. Testing/BUB/2016-17, dated 14-05-2016

Sample Supplied to lab by : Sri. K.S.Chowdareddy, Contractor ,Bangalore

Report required for: Assistant Executive Engineer,
Vidyaranyapura, Sub-Division
BBMP, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm
Grade of Concrete* : M20
Location Concrete* : CC Road

TABLE 1.1 :

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in Mm^2	Maximum Load in K.N	Compressive Strength (N/mm^2)	Avg. Value
1	001	16-04-16	14-05-16	28	22500	530	23.33	**23.70**
	002	"	"	"	"	535	23.77	
	003	"	"	"	"	540	24.00	

*As Furnished by Client.

The Results relate only to the items tested.

G.R. HARISH
Professor
Department of Civil Engineering
Jnana Bharathi Campus
BANGALORE UNIVERSITY
Bangalore-560 056.

Dr. MANJESH .L
ME(Civil Engg.) Ph.D., MISTE, MIRC
Associate Professor
Department of Civil Engineering
Bangalore University, Jnanabharathi Campus,
BANGALORE 560 056.
E-mail: maniesnl@yahoo.com

Phone Off: 080-22961935 / 1946
E-mail: centrans9@gmail.com

FOR QUALITY & EXCELLENCE IN HIGHER EDUCATION
Accredited by NAAC

BANGALORE UNIVERSITY
DEPARTMENT OF CIVIL ENGINEERING

JNANA BHARATHI
BANGALORE - 560 056

BUB/CTE/2016-17/

DATE: 15-05-2016

1. TEST REPORT ON CEMENT CONCRETE CUBES :

Sub: Testing of Concrete Cubes (28days Compressive Strength)
{Project*: Improvements to Roads and Drains at M.S.Palya and surrounding roads in Ward No.11 Vidyaranyapura Sub-Division}

Ref.: Letter No. Testing/BUB/2016-17, dated 14-05-2016

Sample Supplied to lab by : Sri. K.S.Chowdareddy, Contractor ,Bangalore

Report required for: Assistant Executive Engineer,
Vidyaranyapura, Sub-Division
BBMP, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm
Grade of Concrete* : M20
Location Concrete* : CC Road

TABLE 1.1 :

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in Mm^2	Maximum Load in K.N	Compressive Strength (N/mm^2)	Avg. Value
1	001	16-04-16	14-05-16	28	22500	500	22.22	**22.29**
	002	"	"	"	"	515	22.88	
	003	"	"	"	"	490	21.77	

*As Furnished by Client.

The Results relate only to the items tested.

G.R. HARISH
Professor
Department of Civil Engineering
Jnana Bharathi Compus
BANGALORE UNIVERSITY
Bangalore-560 056.

Dr. MANJESH .L
ME(Civil Engg.) Ph.D., MISTE, MIRC
Associate Professor
Department of Civil Engineering
Bangalore University, Jnanabharathi Campus,
BANGALORE 560 056.
E-mail: maniesnl@yahoo.com

Phone Off: 080-22961935 / 1946
E-mail: centrans9@gmail.com

BANGALORE UNIVERSITY
DEPARTMENT OF CIVIL ENGINEERING

JNANA BHARATHI
BANGALORE - 560 056

BUB/CTE/2016-17/

DATE: 17-05-2016

1. TEST REPORT ON CEMENT CONCRETE CUBES :

Sub: Testing of Concrete Cubes (28days Compressive Strength)
{Project*: Improvements to Roads and Drains at M.S.Palya and surrounding roads in Ward No.11 Vidyaranyapura Sub-Division}

Ref.: Letter No. Testing/BUB/2016-17, dated 16-05-2016

Sample Supplied to lab by : Sri. K.S.Chowdareddy, Contractor ,Bangalore

Report required for: Assistant Executive Engineer,
Vidyaranyapura, Sub-Division
BBMP, Bangalore.

RESULTS OF COMPRESSIVE STRENGTH ON CEMENT CONCRETE

CUBE SPECIMENS

Dimensions of Specimen : 150 X 150 X 150mm
Grade of Concrete* : M20
Location* : CC Drain

TABLE 1.1 :

Sl No	Location/ Identification*	Date of Casting*	Date of Testing	Age in Days	C/S Area in Mm^2	Maximum Load in K.N	Compressive Strength (N/mm^2)	Avg. Value
1	001	18-04-16	16-05-16	28	22500	530	23.33	**22.66**
	002	"	"	"	"	515	22.88	
	003	"	"	"	"	490	21.77	

*As Furnished by Client.

The Results relate only to the items tested.

G.R. HARISH
Professor
Department of Civil Engineering
Jnana Bharathi Compus
BANGALORE UNIVERSITY
Bangalore-560 056.

Dr. MANJESH .L
ME(Civil Engg.) Ph.D.. MISTE, MIRC
Associate Professor
Department of Civil Engineering
Bangalore University. Jnanabharathi Campus,
BANGALORE 560 056.
E-mail: maniesnl@yahoo.com